NOTES: MATERIAL: HEAVY GAUGE WELDED STEEL FINISH: POWDER COAT ASA 61 GRAY APPROXIMATE UNPACKAGED RACK WEIGHT: 134 LBS.
FRAME CONSTRUCTION, BATTERY SUPPORT RAIL DESIGN, AND SEISMIC BRACKET OPTIONS
ARE SEISMIC CERTIFIED TO UBC (UNIFORM BUILDING CODE) SECTION 1632. -BATTERIES SHOWN FOR REFERENCE ONLY. SOLD SEPARATELY - 16.25 -**-** 40.11 **-**45.2 ٥ REAR ISO VIEW 38.47 MAX BATTERY CAPACITY BATTERY TYPE QTY 12.25 100 wpc 21 Ø.56 250 wpc - 800 wpc 15 TYP. 3233 W. Kingsley Rd. Ste. 200 Garland, Texas 75041 PH. 972-272-2468 FAX 972-276-9844 <u>BOTTOM VIEW</u> OPTIONAL SEISMIC MOUNTING FOOTPRINT ELECTRONIC SYSTEM SUPPORT 888-475-9292 www.ess.to DIMENSIONS ARE IN INCHES TOLERANCES: ANGULAR: MACH ± .5 BEND ; TWO PLACE DECIMAL ± .02 THREE PLACE DECIMAL ± .01 BATTERY RACK, VRLA, 3 TIER/5 WIDE, SEISMIC Z4 RNA 07-20-09 ROJECTION: THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF ELECTRONIC SYSTEMS SUPPORT. ANY REPRODUCTION IN PART OR AS A WHO SIZE DWG. NO. REV SEE NOTE 1 В R3T5Z4-SPEC EFRODUCTION IN PART OR AS A WH WITHOUT THE WRITTEN PERMISSION OF LECTRONIC SYSTMES SUPPORT IS ROHIBITED. USED ON SCALE: 1:8 WEIGHT: SHEET 1 OF 1 DO NOT SCALE DRAWING