NOTES: MATERIAL: HEAVY GAUGE WELDED STEEL FINISH: POWDER COAT ASA 61 GRAY APPROXIMATE UNPACKAGED RACK WEIGHT: 117 LBS. FRAME CONSTRUCTION, BATTERY SUPPORT RAIL DESIGN, AND SEISMIC BRACKET OPTIONS ARE SEISMIC CERTIFIED TO UBC (UNIFORM BUILDING CODE) SECTION 1632. 2. 3. BATTERIES SHOWN FOR REFERENCE ONLY.
SOLD SEPARATELY— <del>-</del> 16.25 -62.2 REAR ISO VIEW MAX BATTERY CAPACITY BATTERY TYPE QTY 100 wpc 12 250 wpc - 800 wpc 6.13 12.25 \_Ø.56 TYP 3233 W. Kingsley Rd. Ste. 200 Garland, Texas 75041 PH. 972-272-2468 FAX 972-276-9844 ELECTRONIC SYSTEM SUPPORT 888-475-9292 www.ess.to DIMENSIONS ARE IN INCHES TOLERANCES: ANGULAR: MACH ± .5 BEND ±
TWO PLACE DECIMAL ± .02
THREE PLACE DECIMAL ± .01 <u>BOTTOM VIEW</u> OPTIONAL SEISMIC MOUNTING FOOTPRINT BATTERY RACK, VRLA, 4 TIER/2 WIDE, SEISMIC Z4 RNA 07-20-09 ROJECTION: SIZE DWG. NO. REV SEE NOTE 1 В R4T2Z4-SPEC VITHOUT THE WRITTEN PERMISSION OF LECTRONIC SYSTMES SUPPORT IS ROHBITED. USED ON SCALE: 1:8 WEIGHT: SHEET 1 OF 1 DO NOT SCALE DRAWING