NOTES: MATERIAL: HEAVY GAUGE WELDED STEEL FINISH: POWDER COAT ASA 61 GRAY APPROXIMATE UNPACKAGED RACK WEIGHT: 196 LBS. FRAME CONSTRUCTION, BATTERY SUPPORT RAIL DESIGN, AND SEISMIC BRACKET OPTIONS ARE SEISMIC CERTIFIED TO UBC (UNIFORM BUILDING CODE) SECTION 1632. BATTERIES SHOWN FOR REFERENCE ONLY. SOLD SEPARATELY-- 16.25 - 31.11 -79.2 REAR ISO VIEW MAX BATTERY CAPACITY BATTERY TYPE QTY 25 100 wpc - 29.47 250 wpc - 800 wpc 20 6.13 12.25 Ø.56 3233 W. Kingsley Rd. Ste. 200 Garland, Texas 75041 PH. 972-272-2468 FAX 972-276-9844 ELECTRONIC SYSTEM SUPPORT 888-475-9292 www.ess.to DIMENSIONS ARE IN INCHES TOLERANCES: BOTTOM VIEW
OPTIONAL SEISMIC MOUNTING FOOTPRINT ANGULAR: MACH ± .5 BEND ±
TWO PLACE DECIMAL ± .02
THREE PLACE DECIMAL ± .01 BATTERY RACK, VRLA, RNA 07-20-09 ROJECTION: 4 TIER/4 WIDE, SEISMIC Z4 SIZE DWG. NO. REV SEE NOTE 1 В R5T4Z4-SPEC EFRODUCTION IN PART OR AS A WH WITHOUT THE WRITTEN PERMISSION OF LECTRONIC SYSTMES SUPPORT IS ROHIBITED. USED ON SCALE: 1:8 WEIGHT: SHEET 1 OF 1 DO NOT SCALE DRAWING